

Lead in School Drinking Water Report

Dallesport Elementary School

1/19/23



Date(s) collected: 12/17/2022

Date(s) analyzed: 12/22/2022

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373237	Main Building	Other	Test Blank	Test blank	Other	<1
373238	Main Building	Fountain - Multi-Level	Gym	1/2	Water Fountain	<1
373239	Main Building	Fountain	Gym	2/2	Water Fountain	<1
373243	Main Building	Sink	Hallway	1/2	Water Fountain	<1
373244	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway	2/2	Water Bottle Filler	<1
373246	Main Building	Sink	108	1/1	Tap	<1
373247	Main Building	Sink	106	1/1	Tap	<1
373240	Main Building	Sink	111	1/1	Tap	1
373245	Main Building	Sink	105	1/1	Tap	1
373241	Main Building	Sink	100	1/1	Tap	2
373242	Main Building	Sink	101	1/1	Tap	3

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**